

Note this is an information only presentation and all information must be field verified at time of installation

Cornfield Point Focus Area #7

10 Clearwater Rd



- Needs tank and leaching
- 2 bedrooms
- No groundwater, mottles, or ledge

35 Clearwater Rd



- Needs tank and leaching
- 2 Bedrooms
- 37 and 35 Clearwater need to be done at the same time.
- No groundwater, mottles, or ledge

37 Clearwater Rd



- Needs leaching only
- 2 bedrooms
- Need to do 35 Clearwater at the same time.
- No groundwater, mottles or ledge

14 Cottage Rd



- Tank and leaching- Newer tank put in 1992
- Garbage Disposal
- Owner states want to put a pool in the back yard
- No groundwater, mottles, or ledge

41 Indianola Dr



- Needs tank and leaching
- 5 Bedrooms
- Only could go down 84 inches with soil test.

25 Mohican Rd



- Needs tank and leaching
- 3 Bedrooms
- No groundwater, mottles, or ledge

171 Plum Bank Rd



- Needs tank and leaching
- 2 Bedrooms
- Waterline runs up the driveway

173 Plum Bank RD (south house)



- Needs tanks and leaching
- 3 Bedrooms
- Current system is in driveway
- Mottles at 22 inches

173 Plum Bank Rd (north house)



- Needs tank and leaching
- 3 Bedrooms
- Mottles at 22 inches

175 Plum Bank Rd (south house)



- Needs tank and leaching
- 1 bedroom
- Mottles at 30 Inches

175 Plum Bank Rd (north house)



- Needs tank and leaching
- 4 Bedrooms
- Mottles at 30 inches

179 Plum Bank Rd



- Needs tanks and leaching
- 3 Bedrooms

186 Plum Bank Rd



- Needs tank and leaching
- 4 Bedrooms
- Very high ground water

190 Plum Bank Rd



- Needs tank and leaching
- 4 Bedrooms
- Has a catch basin
- Their current system is on neighbor's property

4 Sea Breeze Rd



- Needs tank and leaching
- 2 Bedrooms
- Tank in under the screen porch
- No groundwater, mottles or ledge

6 Sea Breeze Rd



- Needs tank and leaching
- 3 Bedrooms
- No groundwater, mottles, and ledge

7 Sea Breeze Rd



- Needs tank and leaching
- 3 Bedrooms
- No groundwater, mottles, or ledge

8 Sea Breeze Rd



- Needs tank and leaching
- 3 Bedrooms
- System is in the front yard. The outlet pipe runs under the whole house to the front. Can come out the back with the new pipe if needed.
- No groundwater, mottles, or ledge

12 Sea Breeze Rd



- Needs tank and leaching
- 3 Bedrooms
- Backyard has underground oil lines that run from the garage to the house.
- System is in the front yard
- No groundwater, mottles or ledge

14 Sea Breeze Rd



- Tank might be UC and has 4x4s for leaching
- 4 bedrooms
- The washing machine needs to be hitched up to septic line
- No groundwater mottles or ledge

16 Sea Breeze Rd



- Needs leaching only
- 2 Bedrooms
- Garbage disposal
- Test hole only to 78 inches

17 Sea Breeze Rd



- Needs tank and leaching
- 4 Bedrooms
- Original system is in the driveway and owner would like to keep it there.
- Test hole dug to 87 inches

23 Sea Breeze Rd



- Needs tank and leaching
- 3 Bedrooms
- Garbage Disposal
- Tank is in front yard
- Test hole 80 inches

7 Summer Field Rd



- Needs leaching only
- 3 Bedrooms
- Needs test pit